



**LADAKH FIRE & RESCUE SERVICE
PROVISIONAL FIRE SAFETY CERTIFICATE (NOC)**

Application No: FRS/01/2026/00339					
Date of receipt of application	07-08-2026	Date of issue of fire Provisional safety certificate (NOC)	13-08-2026	Valid up to	Till completion & final inspection of the project
Note: please apply before the commencement of construction of the project.					

Certified that the building plan and site plan of	Govt High School Lingshed
Situated at	Lingshed, Leh
Consisting of total	03 Floors, 0 Basement, 1289.936 site area, 506.50 build-up area
Used for (occupancy type)	Educational, School upto senior secondary level

Have been examined and it (building plan and site plan) Shows that the following Fire Prevention and Safety provisions have been provided in the plan: -

01. Fire Extinguishers: 10 fire extinguishers shall be installed on each floor as shown in the proposed building plan.
02. Fire Hose Cabinets: 04 Fire hose cabinets shall be installed as per the proposed school building plan.
03. The width of the approach road and internal roads shall not be less than 30 feet.

Additional Provisions:

In addition to the above, the following provisions shall be made.

- I. The exit doors shall open in the direction of the exit travel.
- II. Terrace Tank 10000 Liters is required.
- III. Fire pump (at terrace level) with a capacity of 450 LPM.
- IV. Staircase minimum two separate exits (minimum 1.5-meter-wide) so arranged that maximum travel distance on the floor shall not exceed 30 meters. Exit doors shall be operated by panic bars.
- V. Emergency lights with an alternate power source are required along all means of egress.
- VI. Public address system shall be installed in the proposed school building.
- VII. Compartmentalization: Maximum 750 m².

This complies with the Fire Prevention and Fire Safety rules applicable in the UT of Ladakh. Hence provisional NOC/ Fire Safety certificate is issued in favor of subject to the following:

1. The owner/ project manager shall ensure the incorporation / installation of all the Fire Safety and Fire Prevention measure as provided in the site plan and building plan as per the relevant IS standards.
2. This NOC is provisional and is subject to inspection on the completion of the project and if the Fire Prevention and Fire Safety measures / installations are not found to be in place, no Fire Safety Certificate/ NOC will be issued.

By order of the DGP/ Director of Fire & Rescue Service


(Mohd Hussain - JKPS)
Deputy Director
Fire & Rescue Service
U.T of Ladakh

NOTE

- i. It is a manually ink-signed certificate.
- ii. For any Query or Verification, Agency/Department/ Office may visit <https://fireservice.ladakh.gov.in> or mail us on ladakhfireservice101@gmail.com
- iii. Tampering of this Certificate will attract penal action.